

Number of samples with concentration greater than the Action Level:

Sample Location ID	Location Type	Location Description	Method Detection Limit	39 Lead First Draw (P)	1 Lead Flush (F)	20 Copper First Draw (P)	21 Copper Flush (F)
006	DW	BUBBLER AT CAFETERIA SINK	0.001	0.0037	Not Sampled	1.337	Not Sampled
007	OT	SINK FACULTY DINING ROOM 334	0.001	0.0028	0.0011	1.839	1.562
008	KI	KITCHEN ICE MACHINE	0.001	ND	Not Sampled	0.0202	Not Sampled
009	NS	NURSE'S SINK	0.001	0.0197	0.0058	1.113	1.516
010	BF	SINK NURSE'S BATHROOM	0.001	0.0122	0.0097	1.278	0.859
011	DW	BUBBLER ROOM 352	0.001	0.079	Not Sampled	1.228	Not Sampled
012	CF	FAUCET ROOM 352	0.001	0.1086	0.0065	1.068	1.136
013	BF	FAUCET BATHROOM RIGHT BETWEEN ROOMS 352/356	0.001	0.0395	0.0101	1.099	1.162
014	BF	FAUCET BATHROOM LEFT BETWEEN ROOMS 352/356	0.001	0.0246	0.003	0.8993	1.125
015	CF	FAUCET ROOM 356	0.001	0.0193	0.0027	0.9608	0.9254
016	DW	BUBBLER ROOM 356	0.001	0.0348	Not Sampled	1.444	Not Sampled
017	DW	BUBBLER ROOM 424	0.001	0.0344	Not Sampled	0.9629	Not Sampled
018	CF	FAUCET ROOM 424	0.001	0.017	0.0026	1.258	1.062
019	BF	FAUCET BATHROOM RIGHT BETWEEN ROOMS 424/416	0.001	0.0311	0.0033	0.898	1.133
020	BF	FAUCET BATHROOM LEFT BETWEEN ROOMS 424/416	0.001	0.0308	0.0025	0.8151	0.8879
021	CF	FAUCET ROOM 420	0.001	0.0208	0.0021	0.5519	1.059
022	DW	BUBBLER ROOM 420	0.001	0.0127	Not Sampled	1.238	Not Sampled
023	BF	FAUCET BOYS ROOM BETWEEN ROOM 420/415	0.001	0.0292	0.0024	0.9154	1.029
024	BF	FAUCET GIRLS ROOM BETWEEN ROOM 420/415	0.001	0.2596	0.0106	0.7626	0.7607
025	DW	BUBBLER ROOM 415	0.001	0.0218	Not Sampled	1.328	Not Sampled
026	CF	FAUCET ROOM 415	0.001	0.0112	0.003	1.094	0.6321
027	CF	FAUCET ROOM 416	0.001	0.0498	0.0042	1.164	0.7385
028	DW	BUBBLER ROOM 416	0.001	0.0121	Not Sampled	1.02	Not Sampled
029	CF	FAUCET ROOM 413	0.001	0.0201	0.0062	0.9636	1.181

Number of samples with concentration greater than the Action Level:

Sample Location ID	Location Type	Location Description	Method Detection Limit	39 Lead First Draw (P)	1 Lead Flush (F)	20 Copper First Draw (P)	21 Copper Flush (F)
030	DW	BUBBLER ROOM 413	0.001	0.039	Not Sampled	0.9415	Not Sampled
031	CF	FAUCET SINK LEFT ROOM 408	0.001	0.0312	0.0046	0.4833	0.9716
033	CF	FAUCET SINK RIGHT ROOM 408	0.001	0.0169	0.0033	0.502	0.781
034	CF	FAUCET ROOM 411	0.001	0.0416	0.0049	1.007	0.8761
035	DW	BUBBLER ROOM 411	0.001	0.014	Not Sampled	1.189	Not Sampled
036	CF	SINK LEFT ROOM 404	0.001	0.0039	ND	1.011	1.361
037	CF	SINK RIGHT ROOM 404	0.001	0.0036	ND	0.799	1.442
038	OT	SINK RIGHT PRE-K KITCHEN	0.001	0.0103	0.0025	2.081	1.348
039	OT	SINK LEFT PRE-K KITCHEN	0.001	0.0059	0.0022	1.607	1.216
040	BF	SINK BATHROOM REAR OF ROOM 404	0.001	0.0025	ND	1.302	1.568
041	BF	SINK BATHROOM REAR OF ROOM 401	0.001	0.0055	0.002	1.136	1.199
042	CF	SINK LEFT ROOM 401	0.001	0.006	0.0018	0.8918	0.8987
043	CF	SINK RIGHT ROOM 401	0.001	0.0077	0.0018	0.5962	0.8755
044	OT	SINK FACULTY PLANNING ROOM 512	0.001	0.0619	0.0207	0.168	0.6013
045	DW	BUBBLER ROOM 506	0.001	0.0377	Not Sampled	0.9659	Not Sampled
046	CF	FAUCET ROOM 506	0.001	0.0136	0.0066	1.183	1.17
047	DW	BUBBLER ROOM 507	0.001	ND	Not Sampled	ND	Not Sampled
048	CF	FAUCET ROOM 507	0.001	0.0406	0.0092	1.172	1.032
049	DW	BUBBLER ROOM 503	0.001	0.063	Not Sampled	1.097	Not Sampled
050	CF	FAUCET ROOM 503	0.001	0.0188	0.0043	1.214	1.037
051	DW	BUBBLER ROOM 504	0.001	0.0363	Not Sampled	0.9863	Not Sampled
052	CF	FAUCET ROOM 504	0.001	0.0099	0.0049	1.118	1.061
053	DW	BUBBLER ROOM 502	0.001	0.093	Not Sampled	1.464	Not Sampled
054	CF	FAUCET ROOM 502	0.001	0.0123	0.0048	1.523	1.014
055	DW	BUBBLER ROOM 501	0.001	0.0239	Not Sampled	1.374	Not Sampled
056	CF	FAUCET ROOM 501	0.001	0.0076	0.0035	1.058	1.012
057	WC	BUBBLER HALL BY GYM 2	0.001	0.0031	0.0038	1.91	1.495
058	OT	SINK ROOM 208 MEDIA ROOM OFF LIBRARY	0.001	0.0041	0.0033	0.0736	0.2456
059	CF	SINK LEFT ROOM 203	0.001	0.0028	ND	0.9973	0.7501

Number of samples with concentration greater than the Action Level:

Sample Location ID	Location Type	Location Description	Method Detection Limit	39 Lead First Draw (P)	1 Lead Flush (F)	20 Copper First Draw (P)	21 Copper Flush (F)
060	CF	SINK RIGHT ROOM 203	0.001	0.0035	ND	1.148	0.7397
061	CF	SINK ROOM 132	0.001	0.0025	ND	1.766	0.9484
062	CF	SINK ROOM 130	0.001	0.0023	ND	1.159	1.016
064	CF	SINK ROOM 128	0.001	0.0022	ND	1.22	1.247
065	CF	SINK ROOM 129 MUSIC	0.001	0.002	ND	0.7215	1.104
066	CF	SINK ROOM 127	0.001	0.0078	0.001	0.7789	2.48
067	CF	SINK ROOM 119	0.001	0.0038	ND	1.488	1.325
068	CF	SINK ROOM 120	0.001	0.0011	ND	1.414	1.179
069	CF	SINK ROOM 118	0.001	0.0037	ND	1.842	1.391
070	CF	SINK ROOM 117	0.001	0.004	ND	1.071	1.325
071	CF	SINK ROOM 115	0.001	0.0021	ND	1.04	1.243
072	CF	SINK ROOM 116	0.001	0.0023	ND	0.9863	1.356
073	CF	SINK ROOM 114	0.001	0.0043	0.0016	1.359	2.02
074	CF	SINK ROOM 112	0.001	0.0033	ND	0.933	1.338
075	CF	SINK ROOM 110	0.001	0.0039	ND	1.122	1.31
076	CF	SINK ROOM 111	0.001	0.0029	ND	1.125	1.266
077	CF	SINK ROOM 109	0.001	0.0019	ND	1.658	1.377
078	CF	SINK ROOM 108	0.001	0.0031	ND	1.101	1.36
079	CF	SINK ROOM 107	0.001	0.0022	ND	0.9934	1.367
080	CF	SINK ROOM 102	0.001	0.0025	ND	1.05	1.78
081	CF	SINK ROOM 101	0.001	0.0015	0.0011	0.9679	1.825
082	DW	BUBBLER ACROSS FROM ROOM 107	0.001	0.0014	ND	2.041	2.09
083	DW	BUBBLER ROOM 234	0.001	0.0272	Not Sampled	1.121	Not Sampled
084	CF	FAUCET ROOM 234	0.001	0.0123	0.0036	1.161	1.016
085	DW	BUBBLER ROOM 233	0.001	0.053	Not Sampled	1.305	Not Sampled
086	CF	FAUCET ROOM 233	0.001	0.0188	0.0055	1.295	1.208
087	DW	BUBBLER ROOM 230	0.001	0.0118	Not Sampled	1.006	Not Sampled
088	CF	FAUCET ROOM 230	0.001	0.0075	0.0045	1.423	1.016
090	CF	FAUCET ROOM 231	0.001	0.0261	0.0046	1.111	0.9689
091	DW	BUBBLER ROOM 228	0.001	0.054	Not Sampled	1.147	Not Sampled
092	CF	FAUCET ROOM 228	0.001	0.0157	0.0103	1.165	0.811
093	DW	BUBBLER ROOM 229	0.001	0.0402	Not Sampled	1.153	Not Sampled
094	CF	FAUCET ROOM 229	0.001	0.0184	0.0067	1.238	0.8889
095	DW	BUBBLER ROOM 227	0.001	0.0269	Not Sampled	1.117	Not Sampled
096	CF	FAUCET ROOM 227	0.001	0.0091	0.0058	1.024	0.7491